



Product Evaluation

RC519 | 1216

Engineering Services Program

The following product has been evaluated for compliance with the wind loads specified in the International Residential Code (IRC) and the International Building Code (IBC).

This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.

This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code, and the Texas Engineering Practice Act.

For more information, contact TDI Engineering Services Program at (800) 248-6032.

Evaluation ID: RC-519

Effective Date: December 1, 2016

Re-evaluation Date: November 2020

Product Name: PBS Steel Roofing Panels Installed Over Steel Purlins or Steel Girts

Manufacturer: ACI Building Systems, LLC
10125 Hwy 6 W
Batesville, MS 38606
(662) 563-4574

General Description:

This evaluation report is for PBS steel panels installed over either steel purlins or steel girts. The metal panels are minimum 24-gauge Galvalume coated steel. The metal panels have 32" of coverage. The metal panels have 7/8" high corrugations which are spaced 2-2/3" on center. The metal panels conform to ASTM A792, Grade 50 Class 1. The metal panels are supplied with an AZ 50 or AZ55 aluminum zinc alloy coating. The metal panels can be supplied painted with silicone polyester products or with Fluropon paint systems.

Limitations:

- **Framing:** Install the metal panels over minimum 16-gauge open steel purlins or steel girts.
- **New Framing Attachment:** The framing shall meet or exceed the wind pressure requirements of the IRC or IBC. Install as required for resistance to wind loads.
- **Design Wind Pressures:** Table 1 specifies the design pressure negative wind load resistance.
- **Installation Over an Existing Roof Covering:** Not permitted.
- **Roof Slope:** If using sealant on the panel side laps, install the metal roofing panels on roofs with a roof slope as low as 1/2:12. If sealant is not used on the panel side laps, then the minimum slope is 3:12.

Table 1: Attachment of Minimum 24-gauge PBS Steel Roofing Panels to Steel Purlins or Steel Girts

16-Gauge Steel Purlins / Girts (Spacing)	Design Wind Pressure (psf)
5'-0" on center	-63.5
4'6" on center	-77.6
4'0" on center	-91.7
3'6" on center	-105.8
3'0" on center	-119.8
2'6" on center	-133.9
2'-0" on center	-148.0

Installation:

- **General:** Install the metal panels in accordance with the manufacturer's recommended installation instructions and this evaluation report.
- **Steel Purlins/Girts:** Table 1 specifies the minimum thickness of steel and the maximum spacing of the purlins/girts.
- **Underlayment:** N/A
- **Attachment of Metal Panels to the Steel Purlins or Steel Girts:** Secure to the steel purlins or girts with No. 12-14 x 1-1/2" long hex head self-drilling screws with a washer. Locate a line of fasteners along each steel purlin or girt spaced 8" on center with the fasteners located in either the valleys or the ridges of the panels. Use fasteners long enough to ensure a minimum penetration of 3 pitches of thread below the steel purlin or girt. Refer to Figure 1 in this evaluation report.
- **Panel Side Laps:** The panels are stitched together with minimum #14-14 x 7/8" hex head screws with a washer. Space the fasteners 24" on center along the length of the side lap.
- **Panel Ends and End Laps to Steel Purlins or Steel Girts:** Minimum No. 12-14 x 1-1/2" hex head screws with a washer. Locate a line of fasteners along the steel purlin or girt spaced 8" on center with the fasteners located in either the valleys or the ridges of the panels. Use fasteners long enough to ensure a minimum penetration of 3 pitches of thread below the steel purlin or girt. Refer to figure 1 for an illustration of the fastener pattern.
- **Panel Edges to the Steel Purlins or Steel Girts:** Minimum No. 12-14 x 1-1/2" hex head screws with a washer. Locate a line of fasteners along the steel purlin or girt spaced 8" on center with the fasteners located in either the valleys or the ridges of the panels. Use fasteners long enough to ensure a minimum penetration of 3 pitches of thread below the steel purlin or girt. Refer to figure 1 for an illustration of the fastener pattern.
- **Trims, Closures, and Accessories:** Install components, such as the eave trim, rake trim, ridge trim, hip trim, and valley trim as required by the manufacturer.

Note: Keep the manufacturer's installation instructions available on the job site during the installation. Use corrosion resistant fasteners as specified in the IRC, IBC, and the Texas Revisions.




Figure 1. Minimum 24-Gauge PBS Panel Fastener Pattern